



Addendum / Clarification # 3

July 27, 2020

BUT-CR 77-5.00, ELK CREEK ROAD BRIDGE REPAIR

Butler County Contract 2020-24

ITEM: 513E95050, STRUCTURAL STEEL, MISC.: 3"x9" 5 GA. CORRUGATED STEEL FLOORING, ASTM A1011-SS-GR50:

The proposed corrugated steel flooring shall be "equal to or better than" specifications contained in the Proposal.

301E46021 ASPHALT CONCRETE BASE, PG70-22M, AS PER PLAN, (4")

The proposed Asphalt Concrete APP shall be PG70-22M and meet the below gradation.

301 APP GRADATION, ASPHALT CONTENT 7%	
SIEVE	% PASSING
2"	100
1 1/2"	100
1"	100
3/4"	100
1/2"	100
3/8"	80-100
# 4	68-78
# 8	
# 16	
# 30	20-50
# 50	
# 100	6-12

BID OPENING:

All SEALED BIDS must be received by the Butler County Engineer not later than 1:00 p.m. local time on Thursday, July 30, 2020. All timely received SEALED BIDS will be **publicly opened at approximately 1:15 p.m.** on that date in the Large Multimedia Conference Room at the Butler County Engineer's Office, 1921 Fairgrove Avenue, Hamilton, Ohio 45011-1965

Please e-mail or call our office when you have received this Addendum.

taylor@mce.org

Melissa Taylor; 513-785-4115